

## Legend

~~Statements removed from the first proposed draft standard~~  
Statements added to the first proposed draft standard  
[Unresolved issue currently being addressed in this round of consultations]

## Introduction

The EcoLogo™ Program Environmental Choice Program (ECP) is pleased to publish the following standard ~~criteria document~~Renewable Low-Impact Electricity Standard-Electricity—Renewable Low-impact.

The ~~Environmental Choice Program~~EcoLogo™ Program is designed to support a continuing effort to improve and/or maintain environmental quality by reducing energy and materials consumption and by minimizing the impacts of pollution generated by the production, use and disposal of goods and services available to ~~Canadians~~ North Americans.

Based on a review of currently available life cycle information of the production, use and disposal stages, the product category requirements will produce an environmental benefit through:

- (a) the displacement of non-renewable fuels by renewable, more sustainable fuel sources;
- (b) the reduction of air emissions that contribute to global warming, climate change, smog, acid rain and air-borne particulate pollution;
- (c) the reduction of solid wastes arising from both the mining and extraction of non-renewable fuel sources, and the disposal of toxic metal emissions and nuclear wastes; and;
- (d) the reduction of impacts on aquatic, riparian and terrestrial ecosystems from electricity generating activities.

Life cycle review is an ongoing process. As information and technology change, the product category requirements will be reviewed and possibly amended.

Environment Canada anticipates that generators and marketers of electricity that conform to this ~~criteria document~~standard will apply to the ~~Environmental Choice Program~~EcoLogo™ Program for verification and subsequent authority to label the qualifying products with the ~~Environmental Choice Program~~EcoLogo™ M™. The ~~ECP~~EcoLogo™ Program maintains verification protocols that clearly define the terminology and associated criteria limits of this ~~criteria document~~standard.

## Notice

Throughout this document, any reference to a standard or guideline means to its latest edition.

The ~~EcoLogo™ Program~~~~Environmental ChoiceM Program (ECP)~~ reserves the right to accept equivalent test data for the test methods specified in this document.

## ~~Notice of Intent~~

~~In respect of future developments of regulatory systems related to climate change, the requirements regarding the disposition of environmental benefits (Section 13) will be reviewed within a two to three year timeframe and possibly changed to reflect new policies and/or regulatory requirements that may emerge.~~

## Interpretation

1. In this ~~set of requirements standard~~, please note the following definitions:

**["alternative-use electricity"]** means electricity generated from the installation of a supplemental process and/or equipment to alter and/or add to the processes of an existing operation in order to generate electricity from a renewable energy source. The existing operation must not have been originally designed or intended for electricity generation, nor have had any processes in place at the time of commissioning that would have facilitated electricity generation. Examples of alternative-use electricity generation sources include, inter alia, irrigation control dams, waterways with locks and waste heat captured from an industrial or commercial process that is fuelled by renewable energy sources. Although certain types of biogas-fuelled electricity (e.g., the capture and combustion of landfill gas) are also forms of alternative-use electricity, biogas-fuelled electricity is defined as a separate category by this ~~criteria document~~~~standard~~;

**"authorized user"** means a final end-use party that is licensed by the EcoLogo™ Program to use the EcoLogo™ Symbol and/or the words "EcoLogo™" and "EcoLogo™ Program" in their own marketing and communications materials.

**"biogas"** means gaseous products (primarily methane and carbon dioxide) produced by the anaerobic decomposition of organic wastes. Facilities producing biogas include inter alia landfill sites, sewage treatment plants and anaerobic digestion organic waste processing facilities;

**"biogas-fuelled electricity"** means electricity generated from a system in which biogases are captured for combustion and conversion to electricity;

**"biomass-fuelled electricity"** means electricity generated through the combustion of clean biomass as it is defined by the ~~EcoLogo™ Program~~~~ECP~~;

**"bundled renewable low-impact electricity"** means a bundled transaction in which the environmental attributes and electricity are sold together;

**"bypassed reach"** means that area in the waterway between the initial point where water has been diverted through turbines or other mechanical means for water-powered electricity generation and the tailrace;

**"CITES"** means the Convention on International Trade in Endangered Species of Wild Fauna and Flora (CITES Secretariat, 15, chemin des Anémones, CH\_1219 Châtelaine-Genève, Suisse. Tel. (+4122) 979 9139/40, fax (+4122) 797 3417);

**“clean biomass”** means organic materials as listed below that have, at no stage in their lifecycle, been treated with organic and/or inorganic substances to change, protect or supplement the physical properties of the materials (including inter alia synthetic chemical pest-control products, fungicides, wood preservatives, paints, varnishes or other surfaces coatings, halogenated compounds and/or compounds containing heavy metals). Specific types of clean biomass recognized under this ~~criteria document~~standard include:

~~(a) the wood wastes and agricultural wastes that are solid residues arising from the harvesting and processing of agricultural crops or forestry products that might otherwise be sent to landfill and/or incinerated;~~

(a) ecologically sustainable amounts of solid biomass removed from fields and forests either as whole plants, parts of plants, or as harvesting residues, and any industrial by-product residues arising from the harvesting and processing of agricultural crops or forestry products that would otherwise be sent to landfills and/or incinerated.

(b) dedicated energy crops,

(c) liquid fuels derived from biomass as defined in items (a) and (b), including inter alia ethanol, biodiesel, and methanol; and

(d) clean organically-sourced material that has been separated from municipal solid waste (MSW), and subsequently processed (e.g., pelletization, gasification) to serve as a combustion fuel.

(e) no biomass by-products with remaining food value

Clean biomass does not include materials for which other diversion methods are a viable alternative (e.g., soil amending, farm land applications, horticultural applications), nor the treated by-products of manufacturing processes (e.g., treated chipwood or plywood, painted woods, pressure treated lumber);

**“CO”** means carbon monoxide, and should be measured using the testing frequency, conditions and methods specified in Appendix 1 of this ~~criteria document~~standard;

**“commercial marketer”** means an entity that generates renewable low-impact electricity and the associated RECs, and then sells or passes on the RECs to commercial clients only (e.g. businesses, institutions, large procurers of electricity, other electricity marketers or generators). A commercial marketer has at least one REC product.

**“concentrating solar thermal technology”** means a system that concentrates the heat of the sun through collectors, and uses the collected heat to drive a generating system to produce electricity;

**“Cumulative Effects Analysis”** means an analysis performed following the Council on Environmental Quality (1997) recommendations

**“Cumulative Effects Assessment”** means a cumulative assessment performed following the Cumulative Effects Assessment Practitioners Guide (The Cumulative Effects Assessment Working Group, 1999)

**“dedicated energy crops”** means those non-food crops grown specifically for their fuel value, and in the case of this ~~criteria document~~standard, for electricity generation. These sources include inter alia short-rotation woody crops (such as poplar trees) and herbaceous energy crops (such as switch grass);

**“de-inking sludge”** means solid material filtered out of the wastewater from the process used to remove ink and other undesirable materials from printed wastepaper;

**“diversion”** means the construction of works to divert water into a canal, tunnel, penstock or similar conduit to supply water for electricity generation purposes;

**“elemental chlorine bleaching”** means the chemical process of purifying and whitening pulp, specifically through the use of chlorine in its gaseous, elemental form (Cl<sub>2</sub>);

“environmental attribute” means the representation of the general environmental benefits resulting from the generation of renewable low-impact electricity. These benefits include inter alia the displacement of non-renewable fuels; the reduction of air emissions; the reduction of solid and nuclear wastes; and the reduction of impacts on aquatic, riparian and terrestrial ecosystems. For EcoLogo™ Renewable Energy Certificates Program, environmental attributes are a qualitative representation; exact quantities of benefits are not represented.

“final end-use party” means the final owner of the REC. An end-use party could be a retail, wholesale or commercial customer, a marketer or a generator. Additionally, a final-end use party could have an on-going contractual agreement for the delivery of a RECs product, or could be receiving a RECs product on a one-time use basis.

“fish habitat” means spawning grounds and nursery, rearing, food supply and migration areas on which fish depend directly or indirectly in order to carry out their life processes;

“fish passage” means both the upstream and downstream migration of fish that can be ensured with the use of natural and/or human-made methods. Human-made methods include inter alia fishways, fish ladders, fish locks, fish elevators, powerhouse collection galleries, diversion screens, and by-pass facilities;

“generator” means an entity that produces electricity;

“greenhouse gas” means a gas that is considered to contribute to global warming and includes, inter alia, carbon dioxide (CO<sub>2</sub>), methane (CH<sub>4</sub>), and nitrous oxide (N<sub>2</sub>O);

“habitat compensation” means replacing habitat which has been subjected to harmful alteration, disruption or destruction with newly created habitat or improving the productive capacity of some other natural habitat;

“harmful alteration, disruption or destruction” means, in respect of fish habitat, any change to fish habitat that reduces, or eliminates, its productive capacity in relation to one or more life processes of fish;

“harvesting and industrial by-products residues” means a form of clean biomass, and includes inter alia:

- (a) mill residues (e.g. residual by-products associated with the processing of forest materials such as bark, sawdust, solid trim, shavings, veneer clippings, clarifier sludge, pulping liquors),
- (b) logging residues (e.g. residual materials left in the forest following harvesting such as slash, sortyard debris, thinning, stumps, roots removed for health reasons),
- (c) crop residues (e.g. materials not needed for soil re-incorporation such as straw, chaff, corn cobs, bean residues, and dried stalks of harvested grain), and
- (d) untreated construction and demolition wastes that cannot be re-used
- (e) no biomass by-products with remaining food value

“head pond” generally means the body of water immediately upstream of the intake structure of electricity generating facilities. Head ponds may be natural or human made (lands inundated and/or water bodies created as a result of the construction of the generating station and/or the associated diversion structure(s)), or a combination thereof. Head ponds may serve one or more purposes including, but not limited to: (i) providing the appropriate hydraulic characteristics, such as submergence, for the intake structure; (ii) increasing the available head of the generating facility; and

(iii) storing water for subsequent discharge through the generating facility. Head ponds also include changes caused by the diversion of a portion of a river through a canal or penstock;

**“hydro-powered electricity”** means electricity generated from a system or technology that uses a mechanical method to capture and convert the potential energy of water into electricity;

**“instream flow”** means the water volume flowing in a waterway;

**“ISO”** means International Organisation for Standardisation;

**“Level A tradeable renewable electricity certificate”** means a TRC that is from a facility that began generating electricity on or after April 1, 2001.

**“Level B tradeable renewable electricity certificate”** means a TRC that is from a facility that began generating electricity from January 1, 1991 to March 31, 2001 inclusive.

**“marketer”** means an entity that receives electricity from a generator(s), possibly combines electricity from various sources, and markets and/or sells the electricity. Note that in some cases, marketers may also be generators;

**“MW”** means megawatt or 100 watts, and a unit of electrical power;

**“MWh”** means megawatt-hour, and a unit of electricity equal to one megawatt of power produced, consumed or flowing for a period of 1 hour;

**“multi-sourced power product”** means a combination of electrical power that is offered by marketers, and is comprised of electricity from more than one source and/or generator, where the sources and/or generators may or may not be certified under this ~~criteria document~~standard;

**“NOX”** means nitrogen oxides, and should be measured using the testing frequency, conditions and methods specified in Appendix 1 of this ~~criteria document~~standard;

**“Null electricity”** means electricity distributed on the grid that has no associated environmental attributes. Once the environmental attributes or RECs have been separated from the renewable low-impact electricity, the electricity becomes “null”. Electricity that does not meet the requirements specified in this RECs Standard is also considered to be “null”.

**“null electricity”** means electricity distributed on the grid that has no associated environmental attributes. Once the environmental attributes have been separated from the electricity - renewable low-impact, the electricity becomes “null”. Electricity that does not meet the requirements specified in this ~~criteria document~~standard is also considered to be “null”;

**“operational air emissions”** means the quantity of air-borne emissions of a specified substance or compound that is released as a result of the generation of electricity;

**“PCDDs and PCDFs”** means polychlorinated dibenzo-para-dioxins and polychlorinated dibenzo-furans, and is a family of chlorinated organic compounds formed as trace contaminants or by-products in industrial processes. This includes the undesirable toxic contaminants generated when chlorine is used in the bleaching of wood pulp and when salt-laden wood is combusted;

**“PM”** means particulate matter, including particulate matter less than or equal to 10 microns in size, and should be measured using the frequency and methods specified in Appendix 1 of this ~~criteria document~~standard;

**“photovoltaic (PV) technology”** means a cell, module, panel, array and/or array field that directly converts light energy from the sun into electricity;

**“renewable”** means replenished through natural processes or through sustainable management practices so that a resource is not depleted at current levels of consumption;

**“Renewable portfolio standard”** or **“RPS”** means a policy that requires electricity suppliers provide retail customers with minimum levels of electricity generated from “new” renewable energy sources. The RSP will usually specify the minimum amount of electricity required (usually as a percentage), the date after which operations must have begun operating and those renewable resources that are eligible for inclusion (e.g. solar photovoltaic, solar thermal electric, wind, wave, tidal, landfill gas, “low emission” biomass).

**“Resale marketer”** means an entity that obtains or purchases a REC product, and then sells or passes it on to the final end-use party(s). A resale marketer may have more than one REC product.

**“Retail/wholesale marketer”** means an entity that generates renewable low-impact electricity and the associated RECs, and then sells or passes on the RECs to retail consumers only. A retail/wholesale marketer has only one REC product.

**“Retirement”** means the final disposition of a REC. RECs are considered retired if: the final end-use party promotes themselves in association with the RECs; if the RECs have been used to meet a regulatory requirement (e.g. cap-and-trade programs, emissions control programs, renewable portfolio standards; or air emission regulatory limits for the generating facility); and if the RECs have been used to meet a non-regulatory mandate (e.g. fulfilling governmental or private sector procurement policies, or calculating another company’s or institution’s portfolio mix).

**“Renewable Energy Certificate”** or **“REC”** means an authorized electronic or paper representation of the environmental attributes associated with the generation of 1 MWh of renewable low-impact electricity. RECs allow the environmental, social and economic attributes of the electricity to be separated from the electricity itself, and passed on or sold as a separate product. For the purposes of this Standard, a REC only represents the environmental attributes associated with the offsetting of null electricity from the grid.

**“riparian”** means the land and habitat found along the banks of streams, rivers and lakes;

**“salt-laden wood”** means timber and forestry residues that have been impregnated with a high concentration of salt (NaCl), either from prolonged exposure to maritime air or from immersion in marine waters (generally for the purpose of transportation);

**“solar-powered electricity”** means electricity generated by converting the sun’s light energy and/or heat energy into electricity, and includes inter alia photovoltaic technologies and concentrating solar thermal technologies;

**“sound environmental management practices”** means those practices and goals used to manage forest and/or agricultural products within a sound environmental management system, as defined in the definitions section of this ~~criteria document~~ **standard**, that have the objectives of maintaining environmental values of the surrounding ecosystem. At a minimum, these practices must address inter alia:

- (a) species selection;
- (b) soil structure, temperature and fertility;
- (c) soil composition rates, compaction and conservation;
- (d) erosion control;
- (e) hauling distance from the harvesting site to the combustion/generation site;

- (f) silvicultural practices and techniques;
- (g) harvesting practices including techniques, rates and waste minimization;
- (h) crop regeneration;
- (i) road/trail construction and maintenance;
- (j) protection of biodiversity, wildlife and rare, threatened and endangered species;
- (k) water quality and quantity;
- (l) watershed conservation and eutrophication control; and
- (m) prior land use.

**“sound environmental management system”** means a system, including inter alia the ISO 14000 series of standards, used to manage forest and/or agricultural products that incorporates sound environmental management practices. At a minimum, system elements must include:

- (a) planning elements such as: identifying forest and/or agricultural resources; identifying environmental aspects; assessing environmental impacts; identifying environmental ~~legislative and regulatory requirements~~ governmental environmental policies, regulations and guidelines and committing to meeting or surpassing these within an adaptive management context; and defining and committing to environmental policies, objectives and targets;
- (b) operational elements such as: defining roles and assigning responsibilities; providing adequate staff training; communicating environmental aspects and policies both internally and externally; implementing an environmental management program based on identified environmental aspects and impacts; documenting all policies, goals and procedures; periodically reviewing and, where necessary, revising the system; performing public consultation and/or outreach; and establishing an environmental emergency preparedness and response plan; and
- (c) monitoring and measurement elements such as: monitoring and measuring key aspects of the system; evaluating and mitigating negative environmental impacts; correcting non-conformance with the management system; performing internal reviews; and having third party audits performed;

The Canadian Standards Association (CSA), the Forest Stewardship Council (FSC) and the Sustainable Forestry Initiative (SFI) forest management certification systems are also specifically recognized as sound environmental management systems used to manage forest products.

**“SOX”** means sulphur oxides, and should be measured using the testing frequency, conditions and methods specified in Appendix 1 of this ~~criteria document~~ standard;

**“species designated as endangered or threatened”** means any species that is listed as either “endangered” or “threatened” on recognized catalogues of such species. In Canada, the default listing shall be that of the federal Committee on the Status of Endangered Wildlife in Canada (i.e. COSEWIC), or relevant federal, provincial, territorial, state and/or local listings (e.g. Ontario’s Committee on the Status of Species at Risk in Ontario; i.e., COSSARO) that supercede the former, where designations are more stringent;

**“tailrace”** means the point at which water is released back into the waterway below a generating station after being passed through turbines or other mechanical means to produce water-powered electricity generation;

**“TEQ”** means toxic equivalent, and is determined by multiplying the measured concentration level of a given congener by the appropriate I-TEF. By converting the measured concentration levels to a common basis, the TEQ quantities may be summed to provide a single representative quantity. For the purposes of this ~~criteria document~~ standard, TEQs are determined for 2,3,7,8-TCDD and 2,3,7,8-TCDF.

The seven congeners for which 2,3,7,8-TCDD TEQs shall be determined are 2,3,7,8-TCDD; 1,2,3,7,8-P5CDD; 1,2,3,4,7,8-H6CDD; 1,2,3,6,7,8-H6CDD; 1,2,3,7,8,9-H6CDD; 1,2,3,4,6,7,8-H7CDD; and OCDD. The ten congeners for which 2,3,7,8-TCDF TEQs shall be determined are

2,3,7,8-TCDF; 1,2,3,7,8-P5CDF; 2,3,4,7,8-P5CDF; 1,2,3,4,7,8-H6CDF; 1,2,3,6,7,8-H6CDF; 2,3,4,6,7,8-H6CDF; 1,2,3,7,8,9-H6CDF; 1,2,3,4,6,7,8-H7CDF; 1,2,3,4,7,8,9-H7CDF; and OCDF.

“tidal & wave-powered electricity” means electricity generated from the kinetic energy delivered by tidal and river currents and from waves nearshore.

“Type A electricity” means renewable low-impact electricity from a generation facility that began generating electricity on or after April 01, 2001.

Incremental increases in electricity generated as a result of either facility upgrades (including inter alia efficiency improvements) or as a result of facility expansions (including inter alia new turbines or arrays) are eligible for Type A designation. In such cases, the average per annum generation capacity prior to the upgrades and/or improvements will provide the baseline on which to calculate the quantity of Type A electricity generation.

Facilities that have been completely decommissioned at any time and re-powered on or after April 01, 2001 are also eligible for Type A designation. Facilities that are decommissioned and re-powered solely to achieve Type A designation will not be granted this designation unless the following conditions are met:

- (c) The facility’s useful life was less than two years prior to its decommissioning.
- (d) More than 75% of the fair market value of the business activity after re-powering is derived from the newly installed equipment and the changes resulting from the re-powering.]

“Type B electricity” means renewable low-impact electricity from a generation facility that began generating electricity from January 01, 1991 to March 31, 2001 inclusive.

Incremental increases in electricity generated as a result of either facility upgrades (including inter alia efficiency improvements) or as a result of facility expansions (including inter alia new turbines or arrays) are eligible for Type B designation. In such cases, the average per annum generation capacity prior to the upgrades and/or improvements will provide the baseline on which to calculate the quantity of Type B electricity generation.

Facilities that have been completely decommissioned at any time and re-powered from January 01, 1991 to March 31, 2001 inclusive are also eligible for Type B designation. Facilities that are decommissioned and re-powered solely to achieve Type B designation will not be granted this designation unless the following conditions are met:

- 1. The facility’s useful life was less than two years prior to its decommissioning.
- 2. More than 75% of the fair market value of the business activity after re-powering is derived from the newly installed equipment and the changes resulting from the re-powering.]

“Type I Electricity” means [EcoLogo™ Program](#)ECP-certified electricity from a generation facility that began operations (e.g. generating electricity) prior to January 01, 1991;]

“Type II Electricity” means [EcoLogo™ Program](#)ECP-certified electricity from a generation facility that began generating electricity from January 01, 1991 to March 31, 2001 inclusive.

Incremental increases in electricity generated as a result of either facility upgrades (including inter alia efficiency improvements) or as a result of facility expansions (including inter alia new turbines or arrays) are eligible for Type II designation. In such cases, the average per annum generation capacity prior to the upgrades and/or improvements will provide the baseline on which to calculate the quantity of Type II electricity generation.

Facilities that have been completely decommissioned at any time and re-powered from January 01, 1991 to March 31, 2001 inclusive are also eligible for Type II designation. Facilities that are decommissioned and re-powered solely to achieve Type II designation will not be granted this designation unless the following conditions are met:

- (a) the facility's useful life was less than two years prior to its decommissioning; and
- (b) more than 75% of the fair market value of the business activity after re-powering is derived from the newly installed equipment and the changes resulting from the re-powering;

["**Type III Electricity**"] means EcoLogo™ Program~~ECP~~-certified electricity from a generation facility that began generating electricity on or after April 01, 2001.

Incremental increases in electricity generated as a result of either facility upgrades (including inter alia efficiency improvements) or as a result of facility expansions (including inter alia new turbines or arrays) are eligible for Type III designation. In such cases, the average per annum generation capacity prior to the upgrades and/or improvements will provide the baseline on which to calculate the quantity of Type III electricity generation.

Facilities that have been completely decommissioned at any time and re-powered on or after April 01, 2001 are also eligible for Type III designation. Facilities that are decommissioned and re-powered solely to achieve Type III designation will not be granted this designation unless the following conditions are met:

- (a) the facility's useful life was less than two years prior to its decommissioning; and
- (b) more than 75% of the fair market value of the business activity after re-powering is derived from the newly installed equipment and the changes resulting from the re-powering;

"**user**" means inter alia an individual, household, commercial or industrial establishment or institutional facility that purchases electricity from either a generator(s) or marketer(s);

~~"**utility**" means any electricity service provider that has "captive" rate-based customers.~~

~~"**water-powered electricity**" means electricity generated from a system or technology that uses a mechanical method to capture and convert the potential energy of water into electricity;~~

"**water quality**" means characteristics of water, specifically including amount of dissolved oxygen, pH, total phosphorus, turbidity, transparency and chlorophyll, and any other item that is critical for or unique to the operating area;

"**wind-powered electricity**" means electricity generated from a wind turbine that converts the kinetic energy of the wind into electricity;

"**wind turbine**" means a system that uses air foils or blades attached to a drive shaft in order to capture the kinetic energy of the wind. The wind pushes against the blades/foils and spins a drive shaft. The drive shaft, either directly or indirectly through a series of gears, moves the generator to produce electricity; and

~~"**wood-wastes and agricultural wastes**" means a form of clean biomass, and includes inter alia:~~

- ~~(a) mill residues (e.g. waste by-products associated with the processing of forest materials such as bark, sawdust, solid trim, shavings, veneer clippings, clarifier sludge, pulping liquors);~~
- ~~(b) logging residues (e.g. residual materials left in the forest following harvesting such as slash, sortyard debris, thinning, stumps, roots);~~
- ~~(c) crop residues (e.g. materials not needed for soil re-incorporation such as straw, chaff, corn cobs, bean residues, and dried stalks of harvested grain); and~~

~~(d) untreated construction and demolition wastes.~~

## Category Definition

2. This category comprises ~~two renewable low-impact electricity products from renewable energy sources~~ which are apt to impose relatively low impacts on the environment and produce potential benefits including, inter alia, low net greenhouse gas emissions, limited or no depletion of non-renewable resources, reduced emissions of other pollutants and reduced impacts on aquatic, riparian and terrestrial ecosystems and species.

These two products are:

- A. Bundled Renewable Low-Impact Electricity
- B. Renewable Energy Certificates

The bundled renewable low-impact electricity and RECs recognized in this standard must come from these generating technologies:

- (a) alternative-use electricity;
- (b) biogas-fuelled electricity;
- (c) biomass-fuelled electricity;
- (d) geothermal-powered electricity;
- (e) hydro-powered electricity;
- (f) solar-powered electricity;
- (g) tidal & wave-powered electricity;
- ~~(g) water-powered electricity; and~~
- (h) wind-powered electricity

These products must also meet the general requirements and product specific requirements outlined in this standard.

## General Requirements

3. To meet the requirements of this ~~sCriteria document~~standard, the renewable low-impact electricity products must:

- (a) meet or exceed all applicable governmental, industrial safety and performance standards; and
- (b) be generated in such a manner that all steps of the process, including the disposal of waste products arising therefrom, will meet the requirements of all applicable governmental acts, by laws and

First published: 2003/12

Last revised: 2006/02

Next Scheduled Review: In process

regulations including, for facilities located in Canada, the Fisheries Act and the Canadian Environmental Protection Act, 1999, (CEPA, 1999).

### **Product Specific Requirements**

4. To meet the requirements of this ~~Criteria document~~standard, the renewable low-impact electricity products must:
  - (a) be accompanied by evidence that appropriate consultation with communities and stakeholders has occurred, issues of concern have been reasonably addressed, and, where applicable, reasonable mitigation of negative impacts has been addressed;
  - (b) be accompanied by evidence that prior or conflicting land use, biodiversity losses and scenic, recreational and cultural values have been addressed during project planning and development;
  - (c) be accompanied by evidence that the project will not result in irreparable/unmitigable degradation or loss of the site's heritage, cultural, recreational and/or touristic values;
  - (d) be generated in a manner that is reliable and practical (e.g. not in research and development stages, actually generating electricity);
  - (e) [be generated by only that proportion of fuel heat input attributed to eligible renewable sources in order to be designated as EcoLogo™ ECP-certified;]
  - (f) be generated in a manner such that no adverse impacts are created for any species designated as endangered or threatened; and
  - (g) meet the criteria and associated definitions in this ~~criteria document~~standard that are applicable to the generation technology employed.
  - (h) demonstrate that cumulative effects have been assessed and potentially mitigated or avoided following a Cumulative Effects Assessment in Canada or a Cumulative Effects Analysis in the United States.
5. To meet the requirements of this ~~criteria document~~standard, **alternative-use electricity** must be generated in such a manner that all applicable certification criteria and definitions in this ~~criteria document~~standard are met. The environmental impacts from the existing operation and the alternative-use process will be reviewed and allocated on a case-by-case basis.
6. To meet the requirements of this ~~Criteria document~~Standard, **biogas-fuelled electricity** must be generated in such a manner that:
  - (a) \_\_\_\_\_-the total of load points assessed for operational air emissions of carbon monoxide (CO), particulate matter (PM), nitrogen oxides (NOX measured as NO2) and sulphur oxides (SOX measured as SO2), as determined in Appendix 2, does not exceed 6.]

In cases where the biogas is used as a partial substitute in a generation facility that is designed to primarily utilize non-renewable fuels, load point calculations will be based only on those operational air emission values that can may be allocated to the combustion of the biogas.

  - (b) \_\_\_\_\_ for farm and food-based biogas systems:

- ii) the highest performance and nutrient management planning standards must be followed
- iii) 75% of phosphorus and nitrogen (by mass) from the systems must be returned to the land while following best nutrient management practices or used in another agronomic or horticultural application (such as producing a compost-like byproduct, pots, bedding)

(c) for landfill gas to energy systems:

50% of functional equipment at the end of the emitting life of a landfill must be re-used.

7. To meet the requirements of this ~~criteria document~~ standard, **biomass-fuelled electricity** must be generated in such a manner that:

[(a) the total of load points assessed for operational air emissions of carbon monoxide (CO), particulate matter (PM), nitrogen oxides (NOX measured as NO<sub>2</sub>) and sulphur oxides (SOX measured as SO<sub>2</sub>), as determined in Appendix 2, does not exceed 6;]

In cases where the clean biomass is used as a partial substitute in a generation facility that is designed to primarily utilize non-renewable fuels, load point calculations will be based only on those operational air emission values that can may be allocated to the combustion of the clean biomass.

(b) if generated from ~~wood-wastes and/or agricultural wastes~~ harvesting and industrial by-products residues, and in cases where the generator and the waste source share common ownership:

- (i) use only ~~wood-wastes and/or agricultural wastes~~ harvesting and industrial by-products residues that have been sourced from operations that have implemented a sound environmental management system and are adhering to sound environmental management practices,
- (ii) ensure the rate of harvest does not exceed levels that can be sustained, and
- (iii) not use ~~wastes~~ harvesting and industrial by-products residues from species that are listed in the CITES Appendices;

~~(c) if generated from clean biomass fuel sources containing salt-laden wood, de-inking sludge or spent pulping liquors from mills using elemental chlorine bleaching, the facility must not emit polychlorinated dioxins and/or furans in excess of one of the following, whichever may be lower:~~

- ~~(i) 100 pg I-TEQ/m<sup>3</sup>; or~~
- ~~(ii) the limits for new pulp and paper boilers burning salt-laden wood as specified in the Canada Wide Standards for Dioxins and Furans (Canadian Council of Ministers of the Environment); and~~

~~(cd)~~ if generated from dedicated energy crops:

- (i) use only dedicated energy crops that have been sourced from operations that have implemented a sound environmental management system and are adhering to sound environmental management practices, and
- (ii) ensure the rate of harvest does not exceed levels that can be sustained.
- iii) at least 5% of the energy crops should be grown organically following the Canadian National Organic Production Standard specified in the Organic Products Regulations (SOR/2006-338) in Canada and the United States Department of Agriculture Organic Standard in the U.S.

(d) in the case where the generator of electricity and the producer of biomass residuals share common ownership, genetically modified products cannot be used.

8. To meet the requirements of this standard, geothermal-powered electricity must be generated in such a manner that:

(a) boron emissions do not surpass 1 ppm in geothermal well waters;

(b) ammonia emissions do not surpass 1 ppm in geothermal well waters;

(c) lead emissions do not surpass 0.01 ppm in geothermal well waters;

(d) cadmium emissions do not surpass 0.005 ppm in geothermal well waters;

(e) radon emissions do not surpass 300 pCi/L in geothermal well waters;

(f) arsenic emissions do not surpass 0.010 ppm in geothermal well waters;

(g) chloride emissions do not surpass 250 mg/L ppm in geothermal well waters;

(h) nickel emissions do not surpass 0.07 ppm in geothermal well waters;

(i) vanadium emissions do not surpass 1 µg/m<sup>3</sup> (averaging time 24 hours) in geothermal steam condensate;

(j) fluoride emissions do not surpass 1.5 ppm in geothermal well waters;

(k) The IFC (2007) Environmental, Health, and Safety Guidelines for Geothermal Power Generation section *Drilling Fluids and Cuttings* is followed; and

(l) The IFC (2007) Environmental, Health, and Safety Guidelines for Geothermal Power Generation section *Well Blowouts and Pipeline Failures* is followed.

9. To meet the requirements of this ~~criteria document~~standard, ~~water~~hydro-powered electricity must be generated in such a manner that the generating facility:

(a) operates in compliance with all regulatory licenses, regulatory requirements and/or other authorizations pertaining to fisheries (including, for facilities located in Canada, the Fisheries Act), without regard to waivers or variances that may be granted or authorized;

(b) operates in compliance with all regulatory licenses, regulatory requirements and/or other authorizations regarding water levels and flows, without regard to waivers or variances that may be granted or authorized;

(c) does not operate under any authorization with terms and conditions allowing the harmful alteration, disruption or destruction of fish habitat unless:

(i) such harmful alteration, disruption or destruction is not affecting the limiting factor controlling productive capacity,

(ii) loss of the affected habitat is compensated by the creation of similar habitat, supporting the same stock, at or near the development site within the same ecological unit

such that the created habitat replaces lost productive capacity, within an approved safety factor.

For facilities located in Canada, these conditional authorizations include those issued under Section 35(2) of the Fisheries Act, by the Minister of Fisheries and Oceans or under regulations made by Governor in Council under the Fisheries Act.

(d) within practical limits and subject to regulatory direction and approval, ensures that plant operations are coordinated with any other water-control facilities that influence water levels and/or flows operating on the same waterway, in order to mitigate impacts and protect indigenous species and the habitat upon which they depend;

(e) as a maximum, causes as much water to flow out of the head pond as is received in any 48-hour period;

In cases where this particular criterion cannot be met, the [EcoLogo™ ProgramECP](#) will nonetheless consider certification if the applicant submits evidence that indicates those hydrological and ecological components key to sustainability of the surrounding watershed are maintained. As a minimum, this evidence must include environmental impact assessments and documentation from a formal public consultation process.

In cases where neither of the above conditions is met, the applicant can opt to apply to a multi-stakeholder and public Electricity Review Process to demonstrate equal or lower adverse environmental impacts.

(f) operates such that reduced water flows in the bypassed reach and reaches downstream of diversion dams and/or dykes are not detrimental to indigenous aquatic and riparian species;

(g) operates such that instream flows downstream of the tailrace are adequate to support downstream indigenous aquatic and riparian species at pre-project ranges;

(h) operates such that water quality in a head pond, a bypassed reach, reaches downstream of the tailrace and reaches downstream of any diversion dams and/or dykes remains comparable to pre-project quality in unaltered bodies of water or waterways within the local watershed;

(i) operates such that any changes in water temperature caused by the facility in the head pond or in reaches downstream of the tailrace or downstream of any diversion dams and/or dykes are not detrimental to indigenous aquatic species;

(j) where a human-made structure is placed across a waterway where no natural barriers exist, provides fish passage when necessary for the purpose of maintaining pre-existing migration patterns for fish communities both upstream and downstream; ~~and-~~

(k) provides any measures (including inter alia trash racks, oversized intake structures designed to slow intake velocities, underwater strobe and sound, fish screens) necessary to minimize fish mortality that would occur through impingement and entrainment;

(l) mercury levels at 100m or less of the generating facility must not exceed 0.001 ppm

10. To meet the requirements of this ~~criteria document~~standard, **solar-powered electricity** must be generated in such a manner that adequate arrangements (i.e., financial reserves) have been made for the proper disposal and/or recycling of all solid waste resulting from the manufacturing of solar cells and of the generation of electricity, including the disposal of batteries of equipment or and machinery or equipment used in the generation process itself, that contains measurable levels of cadmium.
11. To meet the requirements of this standard, tidal and wave-powered electricity must be generated in such a manner that the generating facility:
- (a) does not operate under any authorization with terms and conditions allowing the harmful alteration, disruption or destruction of fish and marine mammal habitat unless such harmful alteration, disruption or destruction is not affecting the limiting factor controlling carrying capacity; and
  - (b) does not cause significant adverse effects on the fundamental hydrodynamic processes of a tidal or wave regime (energy flow, erosion, sediment transportation and deposition) or on biological processes
12. To meet the requirements of this ~~criteria document~~standard, **wind-powered electricity** must be generated in such a manner that:
- (a) the generating facility and its structures are not detrimental to indigenous or migratory avian and bat species;
  - (b) the generating facility and its structures are not located in an area that is protected for avian and bat species designated as endangered or threatened;
  - (c) if generated onshore:
    - (i) ~~construction activities or routine turbine operations do not cause excessive soil erosion such as silting of nearby drainage, streams, ponds, or lakes that would be harmful to aquatic or riparian species and/or increase erosion from steep slopes, plateau edges, or access roadways; and~~
    - (ii) ~~excavated soil is replaced, and uprooted vegetation replanted, after construction or scrapping, where this can be done without interfering with the operation and servicing of the wind facility.~~
  - (d) if generated offshore:
    - (i) the generating facility and its structures are not detrimental to indigenous or migratory marine mammal, fish and shellfish species;
    - (ii) the generating facility and its structures are not located in an area that is protected for marine mammal, fish and shellfish designated as endangered or threatened;
  - (e) adequate arrangements (i.e., financial reserves) have been made for the proper disposal and/or recycling of all solid waste resulting from the generation of electricity.

## Product Specific Requirements

### A. Bundled Renewable Low-Impact Electricity

13. [To meet the requirements of this ~~criteria document~~ standard, marketers of electricity must be able to demonstrate to the satisfaction of the ~~Environmental Choice Program~~ EcoLogo™ Program that the portion of their multi-sourced power product conforming to this ~~criteria document~~ standard incorporates a minimum of 50% Type II Electricity and/or Type III Electricity and a maximum of 50% Type I Electricity.]
14. [~~ECP-certified electricity must be generated by facilities that are also certified and, therefore, meet the general and technology specific requirements of this criteria document.~~ When ~~this~~ certified electricity is sold, the seller must make available upon demand the sources of generation and/or the Type or blend of Types of electricity being sold.]
15. The renewable low-impact electricity must have attached all of the relevant environmental benefits associated with its generation to the full extent possible based on current regulatory and legal requirements. In other words, the renewable low-impact electricity must include all of the environmental benefits associated with the offsetting of the same quantity of null electricity from the grid.
16. Prior to being passed on, transferred or sold to the final end-use party, the environmental benefits or the electricity that generated them must not have been used to meet either regulatory or non-regulatory requirement / mandate, including inter alia:
  - (a) cap-and-trade programs;
  - (b) emissions control programs;
  - (c) renewable portfolio standards;
  - (d) air emission regulatory limits for the generating facility;
  - (e) fulfilling procurement policies; or
  - (f) calculating another company's or institution's portfolio mix.
17. For an electricity product to meet the requirements of this ~~criteria document~~ standard, the rights to these benefits must either be:
  - (a) passed on, transferred or sold to the customer as part of the electricity product in any transaction; or
  - (b) retired by the marketer or seller of the certified electricity such that the environmental benefits may no longer be transferred to, sold to or donated on behalf of any other customer.
18. These environmental benefits cannot be passed on, sold to or retired/donated on behalf of more than one customer.
19. The decision to use (as part of the electricity consumption) or retire the benefits can only be made or agreed to by the customer.

20. The customer can use or retire the environmental benefits one time only. Once the customer has consumed the electricity itself, the environmental benefits are automatically considered retired. Once used or retired, the benefits may no longer be used, sold, donated or claimed in any other way.
21. Electricity products complying with this ~~criteria document~~standard must originate from generation facilities operating in compliance with this criteria document, and cannot comprise electricity from planned generation facilities. Through a verification and auditing process, reconciliation measures will be implemented to ensure that sales levels of complying electricity product do not exceed production/ supply levels.
22. To verify a claim that a product meets the criteria listed in this document, the ~~Environmental Choice Program~~EcoLogo™ Program and its agents will require access, as is its normal practice, to relevant quality control and production records and the right of access to production facilities on an unannounced basis.

It is up to the applicant to provide sufficient information to allow verification of the claim that the facility is in conformity with the ~~criteria document~~standard. In particular, all documentation produced in the context of the environmental assessment of a facility for which certification is sought shall be made available to the EcoLogo™ Program~~ECP~~.

23. Compliance with sections 3(b), 9(a) and 9(b) shall be attested to by a signed statement of the Chief Executive Officer or the equivalent officer of the licensee. Compliance with sections 9(a) and 9(b) shall also be confirmed by additional evidence including inter alia correspondence from the authorized representative of each applicable government body that has issued a license and/or operating permit for the facility.

The ~~Environmental Choice Program~~EcoLogo™ Program shall be advised in writing immediately by the licensee of any noncompliance, which may occur during the term of the license. On the occurrence of any noncompliance, the license may be suspended or terminated as stipulated in the license agreement. In the event of a dispute related to the suspension or termination of the license, the license agreement provides for arbitration.

## B. Renewable Energy Certificates

### Certificates

24. [Green Leaf™ TRCs must be designated as either Level A or Level B by the Green Leaf™ TRCs Program.
- Level A Green Leaf™ TRCs are associated with Level A electricity and are generated by a facility that began operations on or after April 1, 2001.
  - Level B Green Leaf™ TRCs are associated with Level B electricity and are generated by a facility that began operations from January 1, 1991 to March 31, 2001 inclusive.]

### Environmental Attributes

25. Renewable Energy Certificates must have attached all of the relevant environmental attributes associated with the generation of the renewable low-impact electricity to the full extent possible based on current

regulatory and legal requirements. In other words, the RECs must represent all of the environmental attributes associated with the offsetting of the same quantity of null electricity from the grid.

26. Environmental attributes must be associated on a unit-to-unit basis; in other words, one REC unit must have the associated environmental attributes of one megawatt-hour of electricity.
27. Renewable Energy Certificates must be either passed on or sold to the final end-use party (or owner) or be retired on behalf of final end-use party.
28. In no way can the environmental attributes associated with the RECs be counted more than one time.
  - (a) The environmental attributes associated with the renewable low-impact electricity in comparison to the null electricity it offsets from the grid must not have been sold or otherwise separated from the MWh of electricity, and then delivered to any other user besides the final end-use party.
  - (b) Prior to being passed on or sold to the final end-use party, the RECs, the environmental attributes or the electricity that generated them must not have been used to meet a regulatory requirement including *inter alia*:
    - (i) cap-and-trade programs;
    - (ii) emissions control programs;
    - (iii) renewable portfolio standards;
    - (iv) air emission regulatory limits for the generating facility.
  - (c) Prior to being passed on or sold to the final end-use party, the RECs or the electricity that generated them must not have been used to meet a non-regulatory mandate including *inter alia*:
    - (i) fulfilling governmental procurement policies;
    - (ii) fulfilling private sector procurement policies;
    - (iii) calculating another company's or institution's portfolio mix.
  - (d) RECs cannot be passed on, sold to or retired/donated on behalf of more than one final end-use party.
29. RECs cannot be passed on, sold to or retired/donated on behalf of more than one final end-use party.
30. RECs that are generated by facilities receiving or obtaining tax incentive payments are eligible to be designated as "EcoLogo™ RECs" to the extent possible under laws, regulations and contractual arrangements governing the tax incentive programs.

### Electricity Delivery to the Grid

31. The electricity from which the EcoLogo™ RECs came can in no way be represented or sold as “green”, as renewable low-impact or as having low environmental impacts.
32. EcoLogo™ RECs must be sold in blocks of at least 0.1 megawatt-hours per month. This minimum quantity represents approximately 17% of the electricity used by an average household. EcoLogo™ RECs may be sold in blocks larger than this minimum.
33. EcoLogo™ RECs must be generated by the actual amount of electricity delivered to the grid, and not the facility’s capacity.
34. The facility that generated the electricity and associated EcoLogo™ RECs must be connected to grid. Off-line facilities are not eligible to produce EcoLogo™ RECs.

### EcoLogo™ REC Ownership Claims

35. Only the final end-use party (or owner) can make any claims about the RECs. This includes any printed, electronic or broadcast materials.
36. EcoLogo™ RECs can only be claimed, used, retired sold and/or donated by the final end-use party. The decision to claim, use, retire, sell and/or donate the RECs can only be made or agreed to by the final end-use party.
37. The final end-use party can claim, use or retire EcoLogo™ RECs one time only. Once claimed, they may no longer be used, sold, donated or claimed in any other way.
38. EcoLogo™ RECs are considered to be automatically retired when the one of the following actions occurs:
  - (a) A party promotes itself in association with the EcoLogo™ RECs, as owning the RECs, as owning the associated environmental benefits or as participating in the EcoLogo™ RECs Program.
  - (b) The RECs have been used to meet a regulatory requirement including *inter alia*:
    - (i) cap-and-trade programs;
    - (ii) emissions control programs;
    - (iii) renewable portfolio standards;
    - (iv) air emission regulatory limits for the generating facility.
  - (c) The RECs have been used to meet a non-regulatory mandate including *inter alia*:
    - (i) fulfilling governmental procurement policies;
    - (ii) fulfilling private sector procurement policies;
    - (iii) calculating another company’s or institution’s portfolio mix.

39. The final end-use party is eligible to become an Authorized User and use the EcoLogo™ RECs symbol and/or the words “EcoLogo™” or “EcoLogo™ RECs” in their own marketing and communications materials if all of the following conditions are met:
- (a) The final end-use party must have signed an Authorized Use License Agreement with the EcoLogo™ RECs Program.
  - (b) The EcoLogo™ RECs symbol and/or the words “EcoLogo™” or “EcoLogo™ RECs” must be accompanied by a criteria statement indicating the percentage of total electricity load represented by the RECs.
  - (c) The EcoLogo™ RECs Program must review and approve of all marketing and communications materials using EcoLogo™ RECs symbol and/or the words “EcoLogo™” or “EcoLogo™ RECs”.

### EcoLogo™ RECs Sales

40. EcoLogo™ RECs may include only the environmental attributes that are generated in the same calendar year in which the RECs are sold, the first three months of the following calendar year and/or the last six months of the previous calendar year.
41. EcoLogo RECs may be sold on a one-time basis, as opposed to an ongoing contractual basis, so long as the block size is a minimum of 0.1 megawatt-hours. These one-time bases include *inter alia* general usage, trade shows, conferences, receptions and other events.
42. Any party that proposes to or actually sells EcoLogo™ RECs must be a licensee of the EcoLogo™ Program. This includes both initial and downstream sales.
43. All Program licensees must notify the Program of any and all EcoLogo™ RECs transactions and/or sales.
44. Final end-use parties do not have to be licensed by the Program.
45. For a one-time use basis, the final end-use party is eligible to become an Authorized User and use the EcoLogo™ RECs symbol and/or the words “EcoLogo™” or “EcoLogo™ RECs” in their own marketing and communications materials if all of the following conditions are met:
- (a) The methodology used to determine or estimate the percentage of total load must be approved by the EcoLogo™ RECs Program.
  - (b) The final end-use party must have signed an Authorized User Agreement with the EcoLogo™ RECs Program.
  - (c) The EcoLogo™ RECs symbol and/or the words “EcoLogo™” or “EcoLogo™ RECs” must be accompanied by a criteria statement indicating the percentage of total electricity load represented by the RECs.

- (d) The EcoLogo™ RECs symbol and/or the words “EcoLogo™” or “EcoLogo™ RECs” must not be used in a manner that misrepresents either the Program, the reasons for certification or what RECs are.

### Disclosure to Regulators

46. Where law requires notification, the provincial or state energy board and/or agency regulating the generation and sale of electricity must be notified of any EcoLogo™ RECs transaction. This includes the board and/or agency with authority in the areas where the renewable low-impact electricity is generated and where the EcoLogo RECs product is sold, passed on or retired.

### Product Information Disclosure Requirements

47. EcoLogo™ RECs must be accompanied by product disclosure information that includes, as a minimum, the following information:
- (a) a description of what a tradeable renewable electricity certificate is;
  - (b) [the Level of the EcoLogo™ RECs (i.e. Level A or Level B) and a description of what that level means;]
  - (c) the quantity of renewable low-impact electricity that generated the EcoLogo™ RECs (i.e. the number of megawatt-hours);
  - (d) the physical location of the generation facility (i.e. province/state and country);and
  - (e) the resource(s) used to generated the renewable low-impact electricity and the percentages of each used in the generation.
48. The product disclosure information cannot represent that the electrons received by the final end-use party are from a specific electricity generation facility, even though the EcoLogo™ RECs may represent the environmental attributes from that facility.
49. Product disclosure information must be delivered with the EcoLogo™ RECs to the final end-use party with each sale and/or billing invoice.
50. Information clearly explaining what EcoLogo™ RECs are must be provided to any and all customers and final end-use parties prior to their subscription for EcoLogo™ RECs. This applies to all kinds of subscription programs including those that are internet-based.
51. The product disclosure information can be presented as a label, official certificate, information pamphlet and/or website information. A copy of all product disclosure and/or explanatory wording (in its final format for release or publication) must be provided to the EcoLogo™ RECs Program.

52. The EcoLogo™ REC's symbol and/or the words "EcoLogo™" or "EcoLogo™ REC's" must not be used in a manner that misrepresents either the Program, the reasons for certification or what REC's are.

### Verification Requirements

53. The EcoLogo™ REC's Program, TerraChoice and their representative agents shall not, without the Licensee's prior written consent, or except as may be required by law, voluntarily disclose any information obtained that the Licensee advises (in writing at the time such information is obtained) is confidential, unless such information is:
- (a) already known by the EcoLogo™ REC's Program , TerraChoice or their representative agents;
  - (b) otherwise available to the public; or
  - (c) subsequently legally acquired from other sources without any such restriction.
54. To verify that the REC's and the electricity that generated them meet the criteria stipulated in this Standard, the EcoLogo™ REC's Program will require access, as is its normal practice, to relevant quality control, production and transactional records and the right of access to electricity generation facilities on an announced basis.
55. Prior to certification of the REC's, the facility generating the renewable low-impact electricity must be verified and audited by the EcoLogo™ Program to ensure that it meets the general requirements in this standard. If the facility has already been certified as meeting the general requirements in this standard, this initial verification and audit procedure is not required.
56. An audit and verification of all EcoLogo™ REC's transactions must be performed on an annual basis.
57. This audit and verification must be performed by an accredited third party. Internal audits performed by certified internal auditors will not be accepted as ongoing proof of compliance.
58. The verification and audit process will make use of various company documents including, but not limited to, power purchase agreements, contracts, invoices, billing statements and other purchasing documents.
59. EcoLogo™ Program audit checklists, Sufficient Evidence Documents and other verification process documentation must be followed for all verification procedures.
60. The EcoLogo™ Program may perform random surveillance verification of electricity generation facilities and/or the REC's transactions.

### Licensing

61. The Chief Executive Officer or the equivalent officer of the Licensee (retail/wholesale marketer, commercial marketer or resale marketer) must sign a License Agreement for participation in the EcoLogo™ Program.
- (a) Retail/wholesale marketers and commercial marketers must sign a Primary Use License Agreement.
  - (b) Resale marketers must sign a Secondary Use License Agreement.
62. The Chief Executive Officer or the equivalent officer of the Licensee (retail/wholesale marketer, commercial marketer or resale marketer) must sign an Attestation of Compliance that: states:
- (a) all steps of the process required to generate RECs meet the requirements of all applicable governmental acts, by laws and regulations including, for facilities located in Canada, the Fisheries Act and the Canadian Environmental Protection Act (CEPA); and
  - (b) the RECs product to be certified presently meets all applicable criteria as defined in the EcoLogo™ Standard.
63. The EcoLogo™ Program must be advised in writing immediately by the Licensee of any noncompliance that may occur during the term of the license. On the occurrence of any such noncompliance, the license may be suspended or terminated as stipulated in the License Agreement.
64. The Licensee must pay annual fees to the EcoLogo™ Program. These fees are outlined in the EcoLogo™ RECs Fee Schedule.

## Conditions for EcoLogo<sup>GMTM</sup> Use

65. Where compliance with this ~~criteria document standard~~ is established under the ~~Environmental Choice Program~~ EcoLogo™ Program, the EcoLogo™ may appear in association with a product, subject to the following conditions:

- (a) Only those components of a multi-sourced power product that fully satisfy all pertinent EcoLogo™ Program ECP certification and licensing criteria are allowed to be identified as “EcoLogo™ Program ECP-certified” and to carry the EcoLogo™; and
- (b) A criteria statement must appear with the EcoLogo™ whenever the EcoLogo™ is used in association with the electricity during sales and related transactions. The criteria statement must also appear with the EcoLogo™ in other promotional activities and materials.

While the exact wording used in the criteria statement is left to the discretion of the licensee, the statement itself should provide clarification as to why the product was certified. The statement must not misrepresent the product nor the reason it received certification, and must contain at least the following information:

- i) for generators, identification of the amount of EcoLogo™ Program ECP-certified electricity generated and/or marketed in quantitative units (e.g. kWh or MWh);
- ii) for marketers, identification of the amounts of EcoLogo™ Program ECP-certified electricity received from generators and/or supplied to users as either percentages of larger multi-sourced power products or in quantitative units (e.g. kWh or MWh); and
- iii) for users, identification of the amounts of EcoLogo™ Program ECP-certified electricity purchased/used as either percentages of larger multi-sourced power products or in quantitative units (e.g. kWh or MWh).

66. All licensees must comply with the ~~Environmental Choice Program~~ EcoLogo™ Program's Guide to Proper Use of the EcoLogo<sup>MTM</sup> regarding the format and usage of the EcoLogo™.

First published: 2003/12

Last revised: 2006/02

Next Scheduled Review: In process

67. Any accompanying advertising must conform with the relevant requirements stipulated in this ~~Criteria document~~Standard, the license agreement and the ~~Environmental Choice Program~~EcoLogo™ Program's Guide to Proper Use of the EcoLogo~~M~~TM.]

For additional copies of this ~~criteria document~~standard or for more information about the ~~Environmental Choice Program~~EcoLogo™ Program, please contact:

**TerraChoice Environmental Services Inc.,**  
~~1280 Old Innes Road, Suite 400, Ottawa, Ontario, K1B 5M7~~  
Toll Free: 1-800-478-0399, Telephone: (613) 247-1900, ~~Facsimile: (613) 247-2228~~, Email:  
ecoinfo@terrachoice.ca

## Appendix 1: Air Emissions Testing Frequency, Conditions and Methods

Compound / Pollutant	Testing Conditions and Frequency
Carbon monoxide (CO) Nitrogen oxides (NO <sub>x</sub> ) Particulate matter (PM) Sulphur oxides (SO <sub>x</sub> )	<p>Frequency: As determined in the verification protocol negotiated between the <del>Environmental Choice Program</del> <a href="#">EcoLogo™ Program</a> and the generator specifically for each facility.</p> <p>Conditions: Testing must be performed at operational load. Emissions for load point values must be determined from the concentration measurements (ppm (v/v) converted to mg/m<sup>3</sup> at 25°C) and flow rate (dry basis at 101.3 kPa and 25°C) in the duct or stack.</p>

Compound / Pollutant	Testing Methods
Carbon monoxide (CO)	<ul style="list-style-type: none"> <li>(i) <i>Reference Method for the Monitoring of Gaseous Emissions from Fossil Fuel-fired Boilers</i>, Reference Method EPS 1/RM/15, September 1990; or</li> <li>(ii) Continuous Emissions Monitoring (CEMS) Code (REF. 107), Alberta Environment; or</li> <li>(iii) <i>Reference Method for Source Testing: Measurement of Releases of Carbon Monoxide from Stationary Sources</i> (EPS 1/RM/4, 1990) in conjunction with <i>Reference Method for Source Testing: Measurement of Release of Particulate from Stationary Sources</i> (EPS 1/RM/8, 1993), both from Environment Canada; or</li> <li>(iv) Method 10, Determination of Carbon Monoxide Emissions from Stationary Sources, in the Alberta Stack Sampling Code (REF. 89), Alberta Environment.</li> <li>(v) <a href="#">EPA Method 10 - Determination of carbon monoxide emissions from stationary sources, August 2006</a></li> <li>(vi) <a href="#">EPA Method 10A - CO for Certifying CEMS, Determination of carbon monoxide emissions in certifying continuous emission monitoring systems at petroleum refineries, February 2000</a></li> <li>(vii) <a href="#">EPA Method 10B - CO from Stationary Sources, Determination of carbon monoxide emissions from stationary sources, February 2000</a></li> <li>(viii) <a href="#">State of California Air Resources Board (CARB) Reference Method 10 for the Determination of Carbon Monoxide Emissions from Stationary Sources, July 1999</a></li> </ul>
Nitrogen oxides (NO <sub>x</sub> ) measured as NO <sub>2</sub>	<ul style="list-style-type: none"> <li>(i) <i>Reference Method for the Monitoring of Gaseous Emissions from Fossil Fuel-fired Boilers</i>, Reference Method EPS 1/RM/15, September 1990; or</li> <li>(ii) Method 7E, Determination of Nitrogen Oxide Emissions from Stationary Sources, in the Alberta Stack Sampling Code (REF. 89), Alberta Environment; or</li> <li>(iii) Continuous Emissions Monitoring (CEMS) Code (REF. 107), Alberta Environment.</li> <li>(iv) <a href="#">EPA Method 7 - Nitrogen Oxide (NO<sub>x</sub>), Determination of nitrogen oxide emissions from stationary sources, February 2000</a></li> <li>(v) <a href="#">EPA Method 7A - NO<sub>x</sub>, Determination of nitrogen oxide emissions from stationary sources (Ion Chromatographic Method), February 2000</a></li> <li>(vi) <a href="#">EPA Method 7B, Determination of nitrogen oxide emissions from stationary sources (Ultraviolet spectrophotometric method), February 2000</a></li> <li>(vii) <a href="#">EPA Method 7C, Determination of nitrogen oxide emissions from stationary sources (alkaline permanganate/colorimetric method), February 2000</a></li> <li>(viii) <a href="#">EPA Method 7D, Determination of nitrogen oxide emissions from stationary sources(alkaline-permanganate/ion chromatographic method), February 2000</a></li> <li>(ix) <a href="#">EPA Method 7E, Determination of nitrogen oxides emissions from stationary sources (instrumental analyzer procedure), August 2006</a></li> </ul>

Particulate matter (PM)	<ul style="list-style-type: none"> <li>(i) <i>Reference Method for Source Testing: Measurement of Releases of Particulate from Stationary Sources</i>, Reference Method EPS 1/RM/8, December 1993; or</li> <li>(ii) Method 5, <i>Determination of Particulate Emissions from Stationary Sources</i>, in the Alberta Stack Sampling Code (REF. 89), Alberta Environment.</li> <li>(iii) <a href="#">EPA Method 5, Determination of particulate matter emissions from stationary sources, February, 2000</a></li> </ul>
Sulphur oxides (SO <sub>x</sub> ) measured as SO <sub>2</sub>	<ul style="list-style-type: none"> <li>(i) <i>Reference Method for the Monitoring of Gaseous Emissions from Fossil Fuel-fired Boilers</i>, Reference Method EPS 1/RM/15, September 1990; or</li> <li>(ii) Continuous Emissions Monitoring (CEMS) Code (REF. 107), Alberta Environment; or</li> <li>(iii) <i>Reference Method for Source Testing: Measurement of Releases of Sulphur Dioxide from Stationary Sources</i>, Report EPS 1-AP-74-3, September 1975; or</li> <li>(iv) (Method 6C, <i>Determination of Sulphur Dioxide Emissions from Stationary Sources</i>, in the Alberta Stack Sampling Code (REF. 89), Alberta Environment</li> <li>(v) <a href="#">EPA Method 6, Determination of sulfur dioxide emissions from stationary sources, February 2000</a></li> <li>(vi) <a href="#">EPA Method 6C, Determination of sulfur dioxide emissions from stationary sources (instrumental analyzer procedure), August 2006</a></li> <li>(vii) <a href="#">EPA Approved alternative method Alt-001, SO<sub>2</sub> interference in methods 7 and 7A, May 1998</a></li> </ul>
Velocity and Volumetric Flow Rate	<ul style="list-style-type: none"> <li>(i) Method B - <i>Determination of Velocity and Volumetric Flow Rate of Flue Gases, from Reference Method for Source Testing: Measurement of Release of Particulate from Stationary Sources</i> (EPS 1/RM/8, 1993)</li> <li>(ii) <a href="#">Method 2, Determination of stack gas velocity and volumetric flow rate (type s pitot tube), February 2007</a></li> <li>(iii) <a href="#">Method 1, Sample and velocity traverses for stationary sources, February 2007</a></li> </ul>

## Appendix 2: Load Point Determination

The process used to determine the load points for operational air emissions in this ~~criteria document~~[standard](#) is based on a matrix of four environmental air emission parameters, each with a range of values based on actual industry performance. Each level of performance is assigned a specific load point value, and points are then totalled over all parameters. Products with different environmental profiles will thus be able to qualify under this ~~Criteria document~~[Standard](#). The allowable number of points has been set so that, while tradeoffs between parameters is possible, very poor performance in any one parameter will disqualify a generating facility as a supplier of electricity meeting the requirements of this ~~Criteria document~~[Standard](#).

The four parameters used to evaluate electricity generation under this ~~Criteria document~~[Standard](#) for [EcoLogo™ Program](#)~~ECP~~-certification are carbon monoxide (CO), particulate matter (PM), nitrogen oxides (NOX) and sulphur oxides (SOX). Load point calculations will be based on measured air emissions quantities of these compounds that are from measured emissions released as a result of only those operations directly used to generate electricity. The air emission measurements must represent annual emissions normalized to a per MWh basis, and include more than one datum point.

Measured emissions data and the quantity of annual electricity generated should be documented in Part 1: Measured Data, and load points should then be determined by using Part 2: Load Point Calculation. The load

point for each compound should be taken from the top of each column corresponding to the emissions range for that compound's kilogram per MWh value.

### [PART 1: MEASURED DATA

1. Into the table, enter the Annual Quantity of Electricity Generated (in MWh) by the facility. This quantity should be measured net of all parasitic loads from the facility, and net of transformer and line losses up to the point of connection to the utility grid or the user's system (if directly connected).
2. Into the table, enter the Annual Measured Quantity of CO, PM, NOX (measured as NO<sub>2</sub>) and SOX (measured as SO<sub>2</sub>) emitted (in kilograms), noting that appropriate test methods and the prescribed frequency and conditions of testing are provided in Appendix 1 for each compound.
3. Determine the Annual Measured Quantity per MWh of CO, PM, NOX (measured as NO<sub>2</sub>) and SOX (measured as SO<sub>2</sub>) emitted (in kilograms per MWh). These values will be used in the Load Point Calculations in Part 2.

Annual Electricity Generation (in MWh)	Compound	Annual Measured Quantity (in kg)	Annual Measured Quantity per MWh (in kg/MWh)
	CO		
	PM		
	NO <sub>x</sub> (as NO <sub>2</sub> )		
	SO <sub>x</sub> (as SO <sub>2</sub> )		

### PART 2: LOAD POINT CALCULATION

1. Assign the load point value to each compound by taking the value at the top of each column corresponding to the emissions range for that compound's kilogram per megawatt-hour value determined in Part 1.
2. Determine the Total Load Points by summing the four individual load point values.

Compound	Load Points					Assigned Load Points
	0	1	2	3	8	
CO	< 2.15 kg/MWh	2.151 - 3.22 kg/MWh	3.221 - 4.30 kg/MWh	4.301 - 5.37 kg/MWh	> 5.371 kg/MWh	
PM	< 0.228 kg/MWh	0.2281 - 0.387 kg/MWh	0.3871 - 0.516 kg/MWh	0.5161 - 0.645 kg/MWh	> 0.6451 kg/MWh	

NO <sub>x</sub> (as NO <sub>2</sub> )	< 0.77 kg/MWh	0.771 - 1.15 kg/MWh	1.151 - 1.52 kg/MWh	1.521 - 1.90 kg/MWh	> 1.901 kg/MWh	
SO <sub>x</sub> (as SO <sub>2</sub> )	< 0.141 kg/MWh	0.1411 - 0.212 kg/MWh	0.2121 - 0.282 kg/MWh	0.2821 - 0.352 kg/MWh	> 0.3521 kg/MWh	
<b>TOTAL LOAD POINTS</b>						

]

## Addendum: Type IV Electricity Designation

1. ~~The designation of "Type IV electricity" is to be used as an addendum to this EcoLogo Program Environmental ChoiceM Program criteria documentsstandard (CCD-003). This designation exists solely for the purpose of facilitating certain Government of Canada needs with respect to green power purchases:~~

2. ~~To that end:~~

(a) ~~The Type IV designation has no legitimate application beyond those situations in which the Government of Canada is purchasing green power and specifically requesting this designation.~~

(b) ~~Licensees marketing and/or generating electricity meeting the Type IV designation may make reference to this designation only in response to Government of Canada calls for tender for green power, or in communications about a successful sale to the Government of Canada.~~

(c) ~~Initial application for certification under CCD-003 with the Type IV designation must be received at the Environmental ChoiceM Program on or before March 31, 2007.~~

(d) ~~All Type IV designations will expire at the end of any ongoing contract, amended or otherwise, entered into with the Government of Canada. For those licensees with Type IV designation that are not in such an ongoing contract, the designation will expire on March 31, 2008. At that time, the electricity will revert back to Type I, Type II or Type III designations as defined earlier in this criteria documentsstandard.~~

(e) ~~Electricity bearing "Type IV" designation cannot simultaneously bear any other Type designation. For the purposes of compliance with Article 11 of CCD-003, electricity designated as "Type III" can be wholly or partially substituted by electricity designated as "Type IV".~~

3. ~~Article 1 of CCD-003, "Interpretation", is amended to include the following definition:~~

~~**"Type IV Electricity"** means EcoLogo ProgramECP-certified electricity from a generation facility that first began generating electricity on or after April 1, 2001.~~

~~It does not include any restart or recommissioning of a facility, except in those cases where the pre-existing facility ceased production prior to January 1, 1990, and remained out of production until at least April 1, 2001.~~

~~Incremental increases in electricity generated as a result of either facility upgrades or expansions occurring on or after April 1, 2001 (where the facility first began generating electricity prior to April 1, 2001) are also eligible for Type IV designation. In such cases, a representative average per annum amount of electricity generated prior to the upgrades and/or expansions will provide the baseline on which to calculate the quantity of Type IV electricity generation.~~

~~For Type IV electricity, "facility upgrades and expansions" include inter alia any repowering, replacement, refurbishment, upgrading, efficiency improvements, new turbines or arrays, addition of new equipment or components, or other alterations of any pre-existing generation facility. This is applicable even to those pre-existing facilities that have been completely decommissioned, dismantled, removed, otherwise rendered unusable or fallen into disuse through lack of repair or maintenance.~~

~~For greater clarity, "facility upgrades and expansions" include any facility that supplants or replaces a pre-existing facility by accessing the same renewable resource in the same geographic area (for example, the same airshed, water basin, geothermal basin, landfill energy resource, or other biomass source).~~